

ERG-300
March 2000

Engineering Resource Guide



Abbreviations, Fan Terminology and Definitions

- ARR.** Arrangement of fan.
- BHP** Brake horsepower, the fan's power consumption.
- CCW** Counterclockwise. Used to describe the rotation of an impeller. Rotation is determined by viewing the impeller from the drive side on centrifugal fans.
- CFM** Cubic feet per minute, the volume of air moved per minute.
- CL.** Class of fan. The class identifies the limit of the fan's performance range.
- CW** Clockwise. Used to describe the rotation of an impeller. Rotation is determined by viewing the impeller from the drive side on centrifugal fans.
- dBA** Estimated sound pressure level in the space using "A" weighting.
- DWDI** Double width double inlet.
- EFFICIENCY** A Ratio of the useful energy (work) provided by a system to the energy supplied to it. Used to provide a relative performance comparison of fans.
- FPM** Feet per minute, the velocity of the airstream.
- HP** Horsepower, the fan's motor size.
- I.D.** Inside diameter of fan, duct or transition.
- Lp** Sound Pressure Level. Describes the loudness level of the sound, like the brightness level of a light bulb. This value varies with the distance from the sound source and the environment surrounding the sound source. Sound pressure is usually expressed in decibels with a reference level to 0.0002 microbars.
- Lw** Sound Power Level. Describes the total amount of acoustical energy the fan emits, like the watt rating of a light bulb describes the total amount of energy the light emits. This value is independent of location, distance, and environment. Sound power is usually expressed in decibels with a reference level to 10^{-12} watts.
- LwA** Sound Power Level 'A' weighted. This is a single value representing the fan's overall sound power level. 'A' weighting adjusts the sound power level for the response of the human ear. This value is often used in the calculation of sound pressure levels.
- ME** Mechanical efficiency (or Total efficiency). Mechanical efficiency is a ratio of the total fan power output to the power supplied to the fan. Mechanical efficiency uses total pressure, which includes the kinetic energy, to calculate the efficiency.
- O.D.** Outside diameter of fan, duct or transition.
- OV** Outlet velocity, the average air velocity at the outlet of the fan. Outlet velocity is calculated by dividing the CFM by outlet area.
- RPM** Revolutions per minute, the number of rotations the fan shaft makes per minute.
- SE** Static efficiency. Static efficiency is a ratio of the fan power output to the power supplied to the fan. Static efficiency uses static pressure, which does not include the kinetic energy, to calculate the efficiency. It can be found by multiplying the Mechanical efficiency by the ratio of the fan static pressure to the fan total pressure.
- SP** Static pressure is the measure of the potential energy of the airstream. SP acts equally in all directions. It is this pressure in the duct that tends to burst or collapse the duct.
- SWSI** Single width single inlet.
- TP** Total pressure, the measure of the energy content of the airstream. It is the sum of static pressure (SP) and velocity pressure (VP).
- TS** Tip speed, the speed of the fan blade tip.
- VP** Velocity pressure, the measure of the energy content of the airstream. Velocity pressure acts in the direction of the airflow. It is the pressure necessary to accelerate the air.

Formulas For Fan Applications

$$\text{Mechanical Efficiency, ME} = \frac{\text{CFM} \times \text{TP}}{6356 \times \text{BHP}} \times 100$$

$$\text{Static Efficiency, SE} = \frac{\text{CFM} \times \text{SP}}{6356 \times \text{BHP}} \times 100 \quad (\text{where SP is in inches H}_2\text{O})$$

$$\text{Total Pressure, TP} = \text{SP} + \text{VP}$$

$$\text{Velocity, V} = \frac{\text{CFM}}{\text{Area in Sq. Ft.}}$$

$$\text{Velocity Pressure, VP} = \left(\frac{\text{V}}{1096.7} \right)^2 \times \text{density in pounds per cubic foot}$$

$$\text{If the density is } 0.075 \text{ lbs/ft}^3, \text{ the equation for VP reduces to } = \left(\frac{\text{V}}{4005} \right)^2$$

SYSTEM CURVE EQUATION

The following formula is used to find other points on the system line when SP₁ and CFM₁ are known. Most, but not all, systems follow this relationship.

$$\text{SP}_2 = \text{SP}_1 \left(\frac{\text{CFM}_2}{\text{CFM}_1} \right)^2$$

How to Use the Fan Laws for Performance Changes

There are two reasons why a fan's performance may need to be changed:

- The system or area requires additional airflow (CFM).
- The actual system static pressure (SP) is different from the design value.

When these situations occur, it is important to understand how they can affect the fan's performance.

The effect on the fan's performance can be shown by using the Fan Laws, shown below.

FAN LAW EQUATIONS

$$\text{CFM}_2 = \frac{\text{RPM}_2}{\text{RPM}_1} \times \text{CFM}_1$$

$$\text{SP}_2 = \left(\frac{\text{RPM}_2}{\text{RPM}_1} \right)^2 \times \text{SP}_1$$

$$\text{BHP}_2 = \left(\frac{\text{RPM}_2}{\text{RPM}_1} \right)^3 \times \text{BHP}_1$$

Subscript 1 = existing conditions
Subscript 2 = new conditions

EXAMPLE

1. Assume a customer requires a fan to operate at 34,775 CFM at 2.5" SP, at standard air density. Per the specifications, a BI backward inclined fan is required.
2. Based on the above information, from Aerovent's Bulletin 719-C, a 49 BI SWSI, CL. I fan is selected. This fan will operate at 650 RPM and 21.75 BHP to meet the required performance.

3. After installing the fan, the Plant Manager wants to increase the airflow into the plant to 41,500 CFM. The fan laws are used to determine how this fan will be affected by the new system requirements.

4. The known values are

$$\begin{aligned} \text{CFM}_1 &= 34,775 \text{ CFM} & \text{SP}_1 &= 2.5" \text{ SP} \\ \text{CFM}_2 &= 41,500 \text{ CFM} & \text{RPM}_1 &= 650 \text{ RPM} \\ \text{BHP}_1 &= 21.75 \text{ BHP} \end{aligned}$$

5. The unknown values are
- $$\begin{aligned} \text{RPM}_2 &= ?? \\ \text{SP}_2 &= ?? \\ \text{BHP}_2 &= ?? \end{aligned}$$

6. Using the fan law equations, the unknown values are calculated as follows

$$\text{RPM}_2 = \frac{41,500}{34,775} \times 650 = \boxed{776 \text{ RPM}_2}$$

$$\text{SP}_2 = \left(\frac{776}{650} \right)^2 \times 2.5" = \boxed{3.56" \text{ SP}_2}$$

$$\text{BHP}_2 = \left(\frac{776}{650} \right)^3 \times 21.75 = \boxed{37.01 \text{ BHP}_2}$$

7. What does this information tell us?

In order to use the same fan for an airflow of 41,500 CFM, the RPM needs to be increased to 776 RPM.

The new performance increases the fan's horsepower requirement from 25 HP to 40 HP. If the fan is sped up to 776 RPM the motor must be resized.

IMPORTANT NOTE: The new RPM should be checked to make sure it does not exceed the maximum allowable RPM for the fan that is installed.

Temperature & Altitude Correction For Air Density Ratios

In each fan catalog the performance tables are based on standard air density, which is defined as dry air at 70°F at sea level (29.92 Hg barometric pressure). This is equal to 0.075 lb./ft³ density. The fan performance tables provide the fan RPM and brake horsepower requirements for the given CFM and static pressure, at standard air density.

When the fan performance is not at standard conditions, the performance must be converted to standard conditions before entering the fan performance tables. The fan performance is converted to standard conditions by using the correction factor in the Temperature and Altitude Correction Chart shown below.

The following are examples explaining how to convert the fan's performance to standard conditions.

Temperature and Altitude Correction Factors

AIR TEMP °F	ALTITUDE IN FEET ABOVE SEA LEVEL											
	0	1000	2000	3000	4000	5000	6000	7000	8000	9000	10000	15000
	BAROMETRIC PRESSURE IN INCHES OF MERCURY											
	29.92	28.86	27.82	26.82	25.84	24.90	23.98	23.09	22.22	21.39	20.58	16.89
-50	1.293	1.247	1.201	1.159	1.116	1.076	1.036	.997	.960	.924	.889	.729
0	1.152	1.111	1.071	1.032	.995	.959	.923	.889	.856	.824	.792	.650
50	1.039	1.003	.967	.932	.897	.864	.833	.801	.772	.743	.715	.586
70	1.000	.964	.930	.896	.864	.832	.801	.772	.743	.714	.688	.564
100	.946	.912	.880	.848	.818	.787	.758	.730	.703	.676	.651	.534
150	.869	.838	.808	.770	.751	.723	.696	.671	.646	.620	.598	.490
200	.803	.774	.747	.720	.694	.668	.643	.620	.596	.573	.552	.453
250	.747	.720	.694	.669	.645	.622	.598	.576	.555	.533	.514	.421
300	.697	.672	.648	.624	.604	.580	.558	.538	.518	.498	.480	.393
350	.654	.631	.608	.586	.565	.544	.524	.505	.486	.467	.450	.369
400	.616	.594	.573	.552	.532	.513	.493	.476	.458	.440	.424	.347
450	.582	.561	.542	.522	.503	.484	.466	.449	.433	.416	.401	.328
500	.552	.532	.513	.495	.477	.459	.442	.426	.410	.394	.380	.311
550	.525	.506	.488	.470	.454	.437	.421	.405	.390	.375	.361	.296
600	.500	.482	.465	.448	.432	.416	.400	.386	.372	.352	.344	.282
650	.477	.460	.444	.427	.412	.397	.382	.368	.354	.341	.328	.269
700	.457	.441	.425	.410	.395	.380	.366	.353	.340	.326	.315	.258
750	.439	.423	.407	.393	.379	.365	.351	.338	.326	.313	.303	.248
800	.420	.404	.389	.375	.362	.350	.336	.323	.311	.300	.290	.237
850	.404	.391	.376	.363	.349	.336	.324	.312	.300	.289	.279	.228
900	.389	.376	.363	.349	.336	.324	.312	.300	.289	.279	.268	.220
950	.376	.363	.350	.337	.325	.313	.301	.290	.279	.269	.259	.212
1000	.363	.350	.338	.325	.314	.302	.291	.280	.270	.259	.250	.205

How To Convert the Fan's Performance to Standard Conditions

When Operating Conditions Are Known:

Assume a 35 BI, SWSI fan is to handle 17,000 CFM, 2.5" SP, at 300°F and 3000 ft. altitude. This fan is not operating at standard conditions; therefore, the performance needs to be converted to standard conditions to find the fan's speed and brake horsepower. The fan's performance is converted to standard conditions as follows:

- From the table above, the correction factor for 300°F and 3000 ft. altitude is 0.624.
- The static pressure, at standard air density, is calculated by dividing the operating SP by the correction factor; i.e., 2.5" ÷ .624 = 4" SP. The static pressure is 4" at standard air density.
- Knowing the CFM and the static pressure, at standard air density, the fan RPM and BHP can be found. Enter the 35 BI, SWSI fan performance table (Bulletin 719-C) with 17,000 CFM and 4" SP.
- In this example, the RPM and BHP are between the values listed in the performance table; therefore, the RPM and BHP are determined by interpolation. The RPM is determined by the following equation

$$\frac{17,000 - 14,420}{18,025 - 14,420} = \frac{\text{RPM} - 953}{1,032 - 953}$$

- Subtracting the top and bottom values reduces the equation to

$$\frac{2,580}{3,605} = \frac{\text{RPM} - 953}{79}$$

- Dividing the values on the left side and multiplying each side by 79 reduces the equation to

$$0.72 \times 79 = \text{RPM} - 953$$

- Multiplying the values on the left side and adding 953 to each side reduces the equation to

$$56.88 + 953 = \text{RPM}$$

- Solving the left side of the equation results in a fan RPM equal to

$$\text{RPM} = 1,010 \text{ RPM}$$

- Next, the BHP is determined by the following equation

$$\frac{17,000 - 14,420}{18,025 - 14,420} = \frac{\text{BHP} - 12.65}{16.68 - 12.65}$$

- Subtracting the top and bottom values reduces the equation to

$$\frac{2,580}{3,605} = \frac{\text{BHP} - 12.65}{4.03}$$

- Dividing the values on the left side and multiplying each side by 4.03 reduces the equation to

$$0.72 \times 4.03 = \text{BHP} - 12.65$$

- Multiplying the values on the left side and adding 12.65 to each side reduces the equation to

$$2.90 + 12.65 = \text{BHP}$$

- Solving the left side of the equation results in a fan BHP equal to

$$\text{BHP} = 15.55 \text{ BHP}$$

Conclusions — For this example, the required fan RPM is 1,010 RPM and the brake horsepower at standard conditions is 15.55 BHP. The brake horsepower, 15.55 BHP at standard conditions (70°F at sea level), is also referred to as the cold or starting brake horsepower. If the fan is installed at a higher altitude than sea level, such as described in this example, the cold or starting brake horsepower at that altitude is determined by the following equation:

$$\text{Cold BHP at altitude} = \text{BHP}_{\text{std}} \times \text{Correction Factor at Required Elevation and } 70^{\circ}\text{F}$$

For this example, the cold or starting brake horsepower at 3000 ft. altitude and 70°F is

$$15.55 \times 0.896 = 13.93 \text{ BHP, cold BHP @ 3000 ft. altitude}$$

To determine the BHP at operating conditions, 300°F and 3000 ft. altitude, multiply the BHP at standard conditions by the factor for these conditions:

$$15.55 \times 0.624 = 9.70 \text{ BHP at operating conditions, } 300^{\circ}\text{F and } 3000 \text{ ft. altitude}$$

The fan performance information for 17,000 CFM, 2.5" SP, at 300°F and 3000 ft. altitude is

- 1,010 RPM
- 9.76 BHP at operating conditions (300°F and 3000 ft. altitude)
- 13.93 BHP (cold BHP, 70°F and 3000 ft. altitude)
- 15.55 BHP at standard conditions or cold BHP at 70°F and sea level
- 4" SP at standard conditions

When Operating Density Is Known:

Assume a 35 BI, SWSI fan is to handle 23,500 CFM, 3.0" SP, at 0.06364 lb./ft³. This fan is not operating at standard conditions; therefore, the performance needs to be converted to standard conditions to find the fan's speed and brake horsepower. The fan's performance is converted to standard conditions as follows:

- Using the operating density of 0.06364 lb./ft³, the correction factor is determined by dividing the operating density by the standard density, 0.075 lb./ft³.

$$\text{Correction Factor} = \frac{\text{Operating Density}}{\text{Standard Density}} = .848$$

- The static pressure at standard air density is calculated by dividing the operating SP by the conversion factor, i.e., 3.0" ÷ .848 = 3.5" SP. The static pressure is 3.5" at standard air density.
- Knowing the CFM and the static pressure at standard air density, the fan RPM and BHP can be found. Enter the 35 BI, SWSI fan performance table (Bulletin 719-C) with 23,500 CFM and 3.5" SP.
- This example also finds the RPM and BHP between the values listed in the performance table; therefore, the RPM and BHP are determined by interpolation.
- The RPM is determined by the following equation

$$\frac{23,500 - 21,630}{25,235 - 21,630} = \frac{\text{RPM} - 1,111}{1,237 - 1,111}$$

- Subtracting the top and bottom values reduces the equation to

$$\frac{1,870}{3,605} = \frac{\text{RPM} - 1,111}{126}$$

- Dividing the values on the left side and multiplying each side by 126 reduces the equation to

$$0.52 \times 126 = \text{RPM} - 1,111$$

- Multiplying the values on the left side and adding 1,111 to each side reduces the equation to

$$66 + 1,111 = \text{RPM}$$

- Solving the left side of the equation results in a fan RPM equal to

$$\text{RPM} = 1,177 \text{ RPM}$$

- Next, the BHP is determined by the following equation

$$\frac{23,500 - 21,630}{25,235 - 21,630} = \frac{\text{BHP} - 20.09}{26.59 - 20.09}$$

- Subtracting the top and bottom values reduces the equation to

$$\frac{1,870}{3,605} = \frac{\text{BHP} - 20.09}{6.5}$$

- Dividing the values on the left side and multiplying each side by 6.5 reduces the equation to

$$0.52 \times 6.5 = \text{BHP} - 20.09$$

- Multiplying the values on the left side and adding 20.09 to each side reduces the equation to

$$3.38 + 20.09 = \text{BHP}$$

- Solving the left side of the equation results in a fan BHP equal to

$$\text{BHP} = 23.47 \text{ BHP}$$

Conclusions — For this example, the required fan RPM is 1,177 RPM and the brake horsepower is 23.47 BHP at standard conditions. The brake horsepower, 23.47 BHP at standard conditions (70°F at sea level), is also referred to as the cold or starting brake horsepower.

To determine the BHP at operating conditions, multiply the BHP at standard conditions by the conversion factor for these conditions:

$$23.47 \times 0.848 = 19.90 \text{ BHP at operating conditions}$$

The fan performance information for 23,500 CFM, 3.0" SP, at 0.06364 lb./ft³ is

- 1,177 RPM
- 19.90 BHP at operating conditions of 0.06364 lb./ft³
- 23.47 BHP at standard conditions (70°F at sea level)
- 3.5" SP at standard conditions.

Capture Velocities (or Airflow) For Exhaust Hoods

Exhaust hoods are critical devices used to protect workers from pro-cess fumes or dust. Exhaust hoods induce airflow from the work station to the hood to remove contaminants or particles from the work area. The “capture velocity” is the air velocity required to move the contaminants from the work station to the hood. Capture velocities and hood designs depend on the type of fume or dust being removed. Hood designs include canopy hoods, downdraft hoods, booth-type hoods, slot hoods, etc. The chart at right shows the capture velocity and hood design for a given process.

PROCESS	TYPE OF HOOD	AIRFLOW OR CAPTURE VELOCITY
Abrasive Blasting	Downdraft Hood Crossdraft Hood	60-100 CFM/ft ² of Floor 100 CFM/ft ² of Wall
Auto Parking Garage	2 Level	500 CFM/Parking Space
Bag Loading for Grain Elevators, Feed Mills, Flour Mills	Canopy Hood	100 CFM/ft ² Open Face Area 500 FPM Maximum
Ceramic: Dry Pan Dry Press Spraying (Lead Glaze)	Enclosure Hood Local at Die Local at Die At Supply Bin Booth Hood	200 FPM Thru All Openings 500 CFM 500 CFM 500 CFM 400 FPM (Face)
Cooling Tunnels (Foundry)	Enclosure Hood	75-100 CFM Per Running Foot of Enclosure
Core Sanding (on Lathe)	Downdraft Hood Under Work	100 FPM at Source
Crushers & Grinders	Enclosure Hood	200 FPM Thru Openings
Degreasing; Evaporation From Tanks	Canopy Hood	50-100 FPM
Forge (Hand)	Booth Hood	200 FPM at Face
Furniture Stripping Tank	Slot Hood	45 CFM/ft ² of Tank Area
Metal Cutting Bandsaw	Booth Hood	225 CFM/ft ² of Open Area
Metal Spraying	Booth Hood	a) 150 CFM/ft ² of Face Area, Non-toxic b) 200 CFM/ft ² of Face Area, Toxic
Outboard Motor Test Tank	Side Draft Hood	200 CFM/ft ² of tank openings
Packaging Machines	Booth Hood Downdraft Hood Complete Enclosure	50-100 FPM at Face 95-150 FPM Down 100-400 FPM Opening
Paper Machine	Canopy Hood	200-300 FPM at Face
Pickling Metals	Canopy Hood	200-250 FPM
Plating Metals	Canopy Hood	225-250 FPM
Restaurant Range	Hood Against Wall Island Type Hood	80 CFM/ft ² of Hood Area 125 CFM/ft ² of Hood Area
Spray Booth	Booth Hood	a) 200 CFM/ft ² for Face Area Up To 4 ft ² b) 150 CFM/ft ² for Face Area Over 4 ft ²
Steam Kettles	Canopy Hood	150 FPM at Face
Varnish Kettles	Canopy Hood	200-250 FPM at Face
Wire Impregnating	Covered Tanks	200 CFM/ft ² of Opening

Note: The flow rates and velocities shown in the charts on this page are based on standard air density. For conditions with non-standard air such as high temperature, moisture or elevation, adjust the values by dividing by the density ratio.

From American Conference of Governmental Industrial Hygienists: *Industrial Ventilation* (ACGIH®): A Manual of Recommended Practice, 22nd Ed. Copyright 1995, Cincinnati, OH. Reprinted with permission.

Minimum Duct Velocities For Conveying Materials

After the exhaust hood removes the fumes or dust from the work station, the velocity downstream of the hood must be high enough to prevent the material from clogging the ductwork. The velocity downstream of the hood is defined as the *minimum duct velocity* and is determined by the type of material being conveyed through the duct. The table at right shows typical duct velocities for various materials.

MATERIAL	AVG. VELOCITY TO CONVEY MATERIAL (FPM)
VERY FINE LIGHT DUST: Cotton Lint, Wood Flour, Litho Powder	2500-3000
DRY DUSTS & POWDERS: Fine Rubber Dust, Jute Lint, Cotton Dust, Light Shavings, Soap Dust	3000-4000
AVERAGE INDUSTRIAL DUST: Grinding Dust, Buffing Lint-Dry, Wool Jute Dust-Shaker Waste, Shoe Dust, Granite Dust, Silica Flour, General Material Handling, Brick Cutting, Clay Dust, Foundry-General, Limestone Dust, Packaging & Weighing Asbestos Dust in Textile Industries	3500-4000
HEAVY DUSTS Sawdust-Heavy & Wet, Metal Turnings, Foundry Tumbling Barrels & Shake-Out, Sandblast Dust, Wood Blocks, Brass Turnings, Cast Iron Boring Dust, Lead Dust	4000-4500
HEAVY OR MOIST: Lead Dusts with Small Chips, Moist Cement Dust, Asbestos Chunks From Transite Pipe Cutting Machines, Buffing Lint-Sticky, Quick-Lime Dust	4500 & Up

From American Conference of Governmental Industrial Hygienists: *Industrial Ventilation* (ACGIH®): A Manual of Recommended Practice, 22nd Ed. Copyright 1995, Cincinnati, OH. Reprinted with permission.

Air Change Rates for Ventilation

The volume of fresh air (CFM) required to a given area can be easily estimated by the “air change method.” This method is recommended for standard commercial type applications where environmental control of hazards, heat and/or odors is not necessary.

Other items to consider when determining the number of air changes required are:

- Local code requirements on air changes.
- How the space is used.
- The type of climate in the area, e.g., hot, moderate or cold.

The air volume (CFM) can be estimated by using the following equation and the chart at right that defines the number of air changes for given area.

$$\text{Volume of Air} = \frac{\text{Room Volume (ft}^3\text{)}}{\text{No. of Air Changes (min./change)}}$$

AREA TYPE	MINUTES PER CHANGE
ASSEMBLY HALL	3-10
BAKERY	1- 3
BAR	2- 4
BOWLING ALLEY	3- 7
BOILER ROOM	1- 3
CAFETERIA	3- 5
CHURCH	4-10
CLASSROOM	4- 6
ENGINE ROOM	1- 3
FACTORY	2- 7
FORGE SHOP	1- 2
FOUNDRY	1- 5
GENERATOR ROOM	2- 5
HOSPITAL	4- 6
KITCHEN	2- 3
LABORATORY	2- 5
LAUNDRY	2- 4
LOCKER ROOM	4-15
MACHINE SHOP	3- 6
MILL	3- 8
OFFICE	2- 8
RESTAURANT	5-10
RETAIL STORE	5-10
RESTROOM/TOILET	2- 5
TRANSFORMER ROOM	1- 5
WAREHOUSE	4-10

Velocity-to-Velocity Pressure Conversion Chart

Values based at Standard Density, 0.075lbs/ft³.

Calculated by the formula:

$$VP = \left(\frac{V}{4005}\right)^2$$

For other densities use the formula:

$$VP = \left(\frac{V}{1097}\right)^2 \times \text{Density}$$

Where:

V is velocity in ft./min.

Density is in lb/ft³.

V-VELOCITY FPM	VP-VELOCITY PRESSURE IN. WATER	V-VELOCITY FPM	VP-VELOCITY PRESSURE IN. WATER	V -VELOCITY FPM	VP-VELOCITY PRESSURE IN. WATER
100	.0006	2400	.360	4700	1.38
200	.0025	2500	.391	4800	1.44
300	.0056	2600	.423	4900	1.50
400	.010	2700	.456	5000	1.56
500	.016	2800	.490	5100	1.63
600	.023	2900	.526	5200	1.69
700	.031	3000	.563	5300	1.76
800	.040	3100	.601	5400	1.82
900	.051	3200	.640	5500	1.89
1000	.063	3300	.681	5600	1.96
1100	.076	3400	.723	5700	2.03
1200	.090	3500	.766	5800	2.10
1300	.106	3600	.810	5900	2.18
1400	.123	3700	.856	6000	2.25
1500	.141	3800	.903	6100	2.33
1600	.160	3900	.951	6200	2.40
1700	.181	4000	1.00	6300	2.48
1800	.203	4100	1.05	6400	2.56
1900	.226	4200	1.10	6500	2.64
2000	.250	4300	1.16	6600	2.72
2100	.276	4400	1.21	6700	2.81
2200	.303	4500	1.27	6800	2.89
2300	.331	4600	1.32	6900	2.98
				7000	3.06

Definitions of English & Metric Units

°C	= degrees Celsius	in.	= inch	N	= Newton
cfm	= cubic feet per minute	kg	= kilogram	Nm	= Newton-meter
cm	= centimeter	km	= kilometer	oz.	= ounce
°F	= degrees Fahrenheit	kPa	= kilopascal	psi	= pounds per square inch
ft	= foot	l	= liter	rpm	= revolutions per minute
fpm	= feet per minute	lb.	= pound	rps	= revolutions per second
g	= gram	lbf	= pound force	sec.	= second
Hg	= mercury	lb _m	= pound mass	W	= Watts
hp	= horsepower	m	= meter	wg	= water gauge
hpm	= metric horsepower	min.	= minute		
hr.	= hour	mm	= millimeter		

Pressure Equivalent Chart

This chart shows pressure values in inches water gauge and the equivalent pressure in other commonly used unit.

INCHES WATER (IN. WG)	INCHES MERCURY (IN. Hg)	OUNCES PER SQ. IN. (oz/in ²)	POUNDS PER SQ. IN. (lb/in ²)	PASCALS (Pa)	KILOPASCALS (kPa)	MILLIMETERS WATER (mm WG)
1	0.0733	0.577	0.0360	250	0.25	25.4
2	0.1467	1.154	0.0720	500	0.50	50.8
3	0.2200	1.730	0.1081	750	0.75	76.2
4	0.2934	2.307	0.1441	990	0.99	101.6
5	0.3667	2.884	0.1801	1240	1.24	127.0
6	0.4400	3.461	0.2161	1490	1.49	152.4
7	0.5134	4.038	0.2522	1740	1.74	177.8
8	0.5867	4.614	0.2882	1990	1.99	203.2
9	0.6601	5.191	0.3242	2240	2.24	228.6
10	0.7334	5.768	0.3602	2480	2.48	254.0
11	0.8067	6.345	0.3962	2730	2.73	279.4
12	0.8801	6.922	0.4323	2980	2.98	304.8
13	0.9534	7.498	0.4683	3230	3.23	330.2
14	1.027	8.075	0.5043	3480	3.48	355.6
15	1.100	8.652	0.5403	3730	3.73	381.0
16	1.173	9.229	0.5763	3970	3.97	406.4
17	1.247	9.806	0.6124	4220	4.22	431.8
18	1.320	10.382	0.6484	4470	4.47	457.2
19	1.393	10.959	0.6844	4720	4.72	482.6
20	1.467	11.536	0.7204	4970	4.97	508.0
21	1.540	12.113	0.7565	5220	5.22	533.4
22	1.613	12.690	0.7925	5460	5.46	558.8
23	1.687	13.266	0.8285	5710	5.71	584.2
24	1.760	13.843	0.8645	5960	5.96	609.6
25	1.834	14.420	0.9005	6210	6.21	635.0
26	1.907	14.997	0.9366	6460	6.46	660.4
27	1.980	15.574	0.9726	6710	6.71	685.8
28	2.054	16.150	1.009	6950	6.95	711.2
29	2.127	16.727	1.045	7200	7.20	736.6
30	2.200	17.304	1.081	7450	7.45	762.0
31	2.274	17.881	1.117	7700	7.70	787.4
32	2.347	18.458	1.153	7950	7.95	812.8
33	2.420	19.034	1.189	8200	8.20	838.2
34	2.494	19.611	1.225	8440	8.44	863.6
35	2.567	20.188	1.261	8690	8.69	889.0
36	2.640	20.765	1.297	8940	8.94	914.4
37	2.714	21.342	1.333	9190	9.19	939.8
38	2.787	21.918	1.369	9440	9.44	965.2
39	2.860	22.495	1.405	9690	9.69	990.6
40	2.934	23.072	1.441	9930	9.93	1016.0
41	3.007	23.649	1.477	10180	10.18	1041.4
42	3.080	24.226	1.513	10430	10.43	1066.8
43	3.154	24.802	1.549	10680	10.68	1092.2
44	3.227	25.379	1.585	10930	10.93	1117.6
45	3.300	25.956	1.621	11180	11.18	1143.0

English & Metric Conversions

AREA		
MULTIPLY	BY	TO OBTAIN
in ²	0.006944	ft ²
	0.0006452	m ²
ft ²	645.16	mm ²
	144	in ²
	0.09290	m ²
m ²	92903	mm ²
	10.76	ft ²
	1550	in ²
	10 ⁶	mm ²
DENSITY		
MULTIPLY	BY	TO OBTAIN
lb/ft ³	16.02	kg/m ³
kg/m ³	0.06243	lb/ft ³
LENGTH		
MULTIPLY	BY	TO OBTAIN
ft	12	in
	0.3048	m
	304.80	mm
in	0.0833	ft
	0.02540	m
m	25.4	mm
	3.2808	ft
mm	39.37	in
	1000	mm
mm	0.003281	ft
	0.03937	in
	0.001	m
MASS		
MULTIPLY	BY	TO OBTAIN
lb _m	16	oz
	453.59	grams
oz	0.45359	kg
	0.0625	lb _m
grams	28.35	grams
	0.0283	kg
	0.002205	lb _m
kg	0.03527	oz
	0.001	kg
kg	2.2046	lb _m
	35.274	oz
	1000	grams
MOMENT OF INERTIA		
MULTIPLY	BY	TO OBTAIN
lb-in ²	0.0069	lb-ft ²
	0.0002926	kg-m ²
lb-ft ²	144	lb-in ²
	0.04214	kg-m ²
kg-m ²	23.73	lb-ft ²
	3417.2	lb-in ²
POWER		
MULTIPLY	BY	TO OBTAIN
HP	33000	ft-lb/min
	550	ft-lb/s
	745.7	W
	0.7457	kW
ft-lb/min	76.04	kg-m/sec
	0.0000303	HP
	0.167	ft-lb/s
ft-lb/s	0.0226	W
	0.0023	kg-m/sec
	0.0018	HP
W	60	ft-lb/min
	1.3558	W
	0.1388	kg-m/sec
KW	0.00134	HP
	44.254	ft-lb/min
	0.73756	ft-lb/s
KW	0.1019	kg-m/sec
	1.34	HP
	44,254	ft-lb/min
	737.56	ft-lb/s
	101.90	kg-m/sec

POWER		
MULTIPLY	BY	TO OBTAIN
kg-m/sec	0.01	hp
	434.78	ft-lb/min
	7.20	ft-lb/s
	9.81	W

PRESSURE		
MULTIPLY	BY	TO OBTAIN
psi	27.728	in-wg
	2.036	in-Hg
	6894.8	Pa
	704.28	mm-wg
	51.715	mm-Hg
	0.06805	atm
in-wg	0.03607	psi
	0.07343	in-Hg
	248.66	Pa
	25.4	mm-wg
	1.8651	mm-Hg
	0.002454	atm
in-Hg	0.49115	psi
	13.619	in-wg
	3386.4	pa
	345.91	mm-wg
	25.4	mm-Hg
	0.03342	atm
Pa	0.000145	psi
	0.004022	in-wg
	0.0002953	in-Hg
	0.10215	mm-wg
	0.007501	mm-Hg
	0.0000099	atm
mm-wg	0.00142	psi
	0.03937	in-wg
	0.002891	in-Hg
	9.7898	Pa
	0.07343	mm-Hg
	0.0000966	atm
mm-Hg	0.01934	psi
	0.53616	in-wg
	0.03937	in-Hg
	133.32	Pa
	13.619	mm-wg
	0.001316	atm
atm	14.696	psi
	407.48	in-wg
	29.921	invHg
	101300	Pa
	10350	mm-wg
	760	mm-Hg

ROTATING SPEED		
MULTIPLY	BY	TO OBTAIN
RPM	0.0167	rps
	0.0167	Hertz
RPS	60	rpm
	1	Hertz
Hertz	60	rpm
	1	rps

TORQUE		
MULTIPLY	BY	TO OBTAIN
lb-in	0.083	lb-ft
	0.11298	N-m
lb-ft	12	lb-in
	1.3558	N-m
N-m	0.73756	lb-ft
	8.8507	lb-in

TEMPERATURE		
°F = 9/5 C + 32		
°C = 5/9 (F - 32)		

See page 12 for expanded Temperature Conversion table.

VELOCITY		
MULTIPLY	BY	TO OBTAIN
fpm	0.0167	fps
	.2	in/sec
	0.005080	m/s
	0.30480	m/min
fps	60	fpm
	12	in/sec
	0.30480	m/s
	18.288	m/min
in/sec	5	fpm
	0.0833	fps
	0.02540	m/s
	1.524	m/min
m/s	196.85	fpm
	3.2808	fps
	39.37	in/sec
	60	m/min
m/min	3.2808	fpm
	0.05468	fps
	0.65617	in/sec
	0.0167	m/s

VOLUME		
MULTIPLY	BY	TO OBTAIN
ft ³	1728	in ³
	28.317	l
	0.02832	m ³
in ³	0.000579	ft ³
	0.01639	l
	0.0000164	m ³
l	0.03531	ft ³
	61.024	in ³
	0.001	m ³
m ³	35.315	ft ³
	61024	in ³
	1000	l

VOLUME FLOW		
MULTIPLY	BY	TO OBTAIN
CFM	0.0004719	m ³ /sec
	0.02832	m ³ /min
	1.6990	m ³ /hr
	0.47195	l/s
m ³ /sec	28.317	l/min
	2118.9	CFM
	60	m ³ /min
	3600	m ³ /hr
m ³ /min	1000	l/s
	60000	l/min
	35.315	CFM
	0.0167	m ³ /sec
m ³ /hr	60	m ³ /hr
	16.667	l/s
	1000	l/min
	0.58858	CFM
l/s	0.0167	m ³ /min
	0.0003	m ³ /sec
	0.2778	l/s
	16.667	l/min
l/min	2.1189	CFM
	0.001	m ³ /sec
	0.06	m ³ /min
	3.6	m ³ /hr
l/min	60	l/min
	0.03531	CFM
	0.000016	m ³ /sec
	0.001	m ³ /min
l/min	0.06	m ³ /hr
	0.0167	l/s

Friction Loss Per 100 Feet of Round Duct

Data is for duct roughness of 0.0005 feet. If a special duct material is being used, please contact the duct material manufacturer for the friction losses. Friction loss in inches H₂O.

VEL.	DUCT DIAMETER													
	4"		5"		6"		7"		8"		10"		12"	
	CFM	FL	CFM	FL	CFM	FL	CFM	FL	CFM	FL	CFM	FL	CFM	FL
2000	175	1.85	273	1.39	393	1.11	535	0.92	698	0.77	1091	0.59	1571	0.47
2200	192	2.21	300	1.67	432	1.33	588	1.10	768	0.93	1200	0.71	1728	0.56
2400	209	2.59	327	1.97	471	1.57	642	1.30	838	1.10	1309	0.83	1885	0.67
2600	227	3.04	355	2.30	511	1.83	695	1.51	908	1.28	1418	0.97	2042	0.78
2800	244	3.49	382	2.65	550	2.11	748	1.74	977	1.47	1527	1.12	2199	0.90
3000	262	4.00	409	3.02	589	2.41	802	1.99	1047	1.68	1636	1.28	2356	1.02
3200	279	4.52	437	3.43	628	2.72	855	2.25	1117	1.91	1745	1.45	2513	1.16
3400	297	5.10	464	3.85	668	3.07	909	2.53	1187	2.15	1854	1.63	2670	1.30
3600	314	5.68	491	4.30	707	3.43	962	2.83	1257	2.40	1963	1.82	2827	1.45
3800	332	6.33	518	4.77	746	3.80	1016	3.14	1327	2.66	2073	2.02	2985	1.62
4000	349	6.97	546	5.28	786	4.21	1069	3.47	1396	2.94	2182	2.23	3142	1.79
4200	367	7.69	573	5.80	825	4.62	1123	3.82	1466	3.23	2291	2.46	3299	1.96
4400	384	8.39	600	6.35	864	5.05	1176	4.17	1536	3.54	2400	2.69	3456	2.15
4600	402	9.18	627	6.91	903	5.51	1230	4.56	1606	3.86	2509	2.93	3613	2.34
4800	419	9.95	655	7.53	943	5.99	1283	4.95	1676	4.19	2618	3.18	3770	2.54
5000	437	10.80	682	8.14	982	6.49	1337	5.36	1746	4.54	2727	3.45	3927	2.76
5200	454	11.63	709	8.78	1021	7.00	1390	5.78	1815	4.90	2836	3.72	4084	2.97
5400	471	12.50	737	9.47	1061	7.54	1443	6.22	1885	5.27	2945	4.00	4241	3.20
5600	489	13.45	764	10.16	1100	8.10	1497	6.68	1955	5.66	3054	4.30	4398	3.44
5800	506	14.37	791	10.88	1139	8.67	1550	7.15	2025	6.07	3163	4.61	4555	3.68
6000	524	15.39	818	11.62	1178	9.26	1604	7.65	2095	6.48	3272	4.92	4712	3.93
6200	541	16.38	846	12.41	1218	9.88	1657	8.15	2164	6.91	3381	5.25	4869	4.20
6400	559	17.47	873	13.19	1257	10.51	1711	8.68	2234	7.35	3491	5.59	5027	4.47
6600	576	18.52	900	14.00	1296	11.16	1764	9.22	2304	7.81	3600	5.93	5184	4.74
6800	594	19.68	928	14.87	1336	11.84	1818	9.78	2374	8.28	3709	6.29	5341	5.03
7000	611	20.80	955	15.73	1375	12.53	1871	10.34	2444	8.77	3818	6.66	5498	5.32

VEL.	DUCT DIAMETER													
	14"		16"		18"		20"		22"		24"		30"	
	CFM	FL	CFM	FL	CFM	FL	CFM	FL	CFM	FL	CFM	FL	CFM	FL
2000	2138	0.39	2793	0.33	3534	0.29	4363	0.25	5280	0.22	6283	0.20	9817	0.15
2200	2352	0.47	3072	0.40	3888	0.34	4800	0.30	5808	0.27	6912	0.24	10799	0.19
2400	2566	0.55	3351	0.47	4241	0.41	5236	0.36	6336	0.32	7540	0.29	11781	0.22
2600	2779	0.64	3630	0.55	4595	0.47	5672	0.42	6863	0.37	8168	0.33	12763	0.26
2800	2993	0.74	3910	0.63	4948	0.55	6109	0.48	7391	0.43	8796	0.39	13744	0.29
3000	3207	0.85	4189	0.72	5302	0.62	6545	0.55	7919	0.49	9425	0.44	14726	0.34
3200	3421	0.96	4468	0.82	5655	0.71	6981	0.62	8447	0.55	10053	0.50	15708	0.38
3400	3635	1.08	4747	0.92	6008	0.79	7418	0.70	8975	0.62	10681	0.56	16690	0.43
3600	3848	1.20	5027	1.02	6362	0.89	7854	0.78	9503	0.70	11310	0.63	17671	0.48
3800	4062	1.34	5306	1.14	6715	0.99	8290	0.87	10031	0.77	11938	0.70	18653	0.53
4000	4276	1.48	5585	1.26	7069	1.09	8727	0.96	10559	0.85	12566	0.77	19635	0.59
4200	4490	1.63	5864	1.38	7422	1.20	9163	1.05	11087	0.94	13195	0.84	20617	0.65
4400	4704	1.78	6144	1.51	7776	1.31	9599	1.15	11615	1.03	13823	0.92	21598	0.71
4600	4917	1.94	6423	1.65	8129	1.43	10036	1.26	12143	1.12	14451	1.01	22580	0.77
4800	5131	2.11	6702	1.79	8483	1.55	10472	1.37	12671	1.22	15080	1.10	23562	0.84
5000	5345	2.28	6982	1.94	8836	1.68	10909	1.48	13199	1.32	15708	1.19	24544	0.91
5200	5559	2.46	7261	2.09	9189	1.81	11345	1.60	13727	1.42	16336	1.28	25525	0.98
5400	5773	2.65	7540	2.25	9543	1.95	11781	1.72	14255	1.53	16965	1.38	26507	1.05
5600	5986	2.85	7819	2.42	9896	2.10	12218	1.85	14783	1.64	17593	1.48	27489	1.13
5800	6200	3.05	8099	2.59	10250	2.25	12654	1.98	15311	1.76	18221	1.58	28470	1.21
6000	6414	3.26	8378	2.77	10603	2.40	13090	2.11	15839	1.88	18850	1.69	29452	1.29
6200	6628	3.48	8657	2.95	10957	2.56	13527	2.25	16367	2.01	19478	1.81	30434	1.38
6400	6842	3.70	8936	3.14	11310	2.72	13963	2.40	16895	2.14	20106	1.92	31416	1.47
6600	7055	3.93	9216	3.34	11664	2.89	14399	2.55	17423	2.27	20735	2.04	32397	1.56
6800	7269	4.16	9495	3.54	12017	3.07	14836	2.70	17951	2.40	21363	2.16	33379	1.65
7000	7483	4.41	9774	3.75	12370	3.25	15272	2.86	18479	2.55	21991	2.29	34361	1.75

Area and Circumference of Circles

DIA. (IN.)	AREA		CIRCUM- FERENCE	
	IN ²	FT ²	IN	FT
1	0.785	0.005	3.14	0.262
2	3.14	0.022	6.28	0.523
3	7.07	0.049	9.42	0.785
4	12.57	0.087	12.57	1.054
5	19.63	0.136	15.71	1.31
6	28.27	0.196	18.85	1.57
7	38.48	0.267	21.99	1.83
8	50.27	0.349	25.13	2.09
9	63.62	0.441	28.27	2.36
10	78.54	0.545	31.42	2.62
11	95.03	0.659	34.56	2.88
12	113.00	0.785	37.70	3.14
13	133.00	0.921	40.84	3.40
14	154.00	1.07	43.98	3.66
15	177.00	1.23	47.12	3.93
16	201.00	1.40	50.27	4.19
17	227.00	1.57	53.41	4.45
18	254.00	1.77	56.55	4.71
19	284.00	1.97	59.69	4.97
20	314.00	2.18	62.83	5.23
21	346.00	2.40	65.97	5.50
22	380.00	2.64	69.12	5.76
23	415.00	2.88	72.26	6.02
24	452.00	3.14	75.40	6.28
25	491.00	3.41	78.54	6.54
26	531.00	3.68	81.68	6.80
27	573.00	3.97	84.82	7.07
28	616.00	4.27	87.96	7.33
29	661.00	4.58	91.11	7.59
30	707.00	4.90	94.25	7.85
31	755.00	5.24	97.39	8.11
32	804.00	5.58	100.53	8.37
33	855.00	5.93	103.67	8.64
34	908.00	6.30	106.81	8.90

DIA. (IN.)	AREA		CIRCUM- FERENCE	
	IN ²	FT ²	IN	FT
35	962	6.68	109.96	9.16
36	1018	7.06	113.10	9.42
37	1075	7.46	116.24	9.68
38	1134	7.87	119.38	9.94
39	1195	8.29	122.52	10.21
40	1257	8.72	125.66	10.47
41	1320	9.16	128.81	10.73
42	1385	9.61	131.95	10.99
43	1452	10.08	135.09	11.25
44	1521	10.55	138.23	11.51
45	1590	11.04	141.37	11.78
46	1662	11.53	144.51	12.04
47	1735	12.04	147.65	12.30
48	1810	12.56	150.80	12.56
49	1886	13.08	153.94	12.82
50	1963	13.62	157.08	13.08
51	2043	14.17	160.22	13.35
52	2124	14.74	163.36	13.61
53	2206	15.31	166.50	13.87
54	2290	15.89	169.65	14.13
55	2376	16.49	172.79	14.39
56	2463	17.09	175.93	14.65
57	2552	17.71	179.07	14.92
58	2642	18.33	182.21	15.18
59	2734	18.97	185.35	15.44
60	2827	19.62	188.50	15.70
61	2922	20.28	191.64	15.96
62	3019	20.95	194.78	16.23
63	3117	21.63	197.92	16.49
64	3217	22.32	201.06	16.75
65	3318	23.03	204.20	17.01
66	3421	23.74	207.35	17.27
67	3526	24.46	210.49	17.53
68	3632	25.20	213.63	17.80

DIA. (IN.)	AREA		CIRCUM- FERENCE	
	IN ²	FT ²	IN	FT
69	3739	25.95	216.77	18.06
70	3848	26.70	219.91	18.32
71	3959	27.47	223.05	18.58
72	4072	28.25	226.19	18.84
73	4185	29.04	229.34	19.10
74	4301	29.84	232.48	19.37
75	4418	30.66	235.62	19.63
76	4536	31.48	238.76	19.89
77	4657	32.31	241.90	20.15
78	4778	33.16	245.04	20.41
79	4902	34.01	248.19	20.67
80	5027	34.88	251.33	20.94
81	5153	35.76	254.47	21.20
82	5281	36.64	257.61	21.46
83	5411	37.54	260.75	21.72
84	5542	38.45	263.89	21.98
85	5675	39.37	267.04	22.24
86	5809	40.31	270.18	22.51
87	5945	41.25	273.32	22.77
88	6082	42.20	276.46	23.03
89	6221	43.17	279.60	23.29
90	6362	44.14	282.74	23.55
91	6504	45.13	285.88	23.81
92	6648	46.13	289.03	24.08
93	6793	47.14	292.17	24.34
94	6940	48.15	295.31	24.60
95	7088	49.18	298.45	24.86
96	7238	50.23	301.59	25.12
97	7390	51.28	304.73	25.38
98	7543	52.34	307.88	25.65
99	7698	53.41	311.02	25.91
100	7854	54.50	314.16	26.17

Equations: Area = πr^2 (r = radius of circle)

Circumference = $2\pi r$ or πd (r = radius of circle; d = diameter of circle)

Gauges & Equivalent Metal Thickness

Steel Sheet Gauges & Weights

GAUGE	THICKNESS		WEIGHT	
	IN.	MM	LB/FT ²	KG/M ²
1"	1	25.4000	41.829	204.379
3/4"	3/4	19.0500	31.372	153.280
5/8"	5/8	15.8750	26.143	127.73
1/2"	1/2	12.7000	20.915	102.187
3/8"	3/8	9.5250	15.686	76.640
5/16"	5/16	7.9375	13.072	63.867
1/4"	1/4	6.3500	10.457	51.093
3/16"	3/16	4.7625	7.843	38.320
7	.1793	4.5542	7.500	36.644
8	.1644	4.1758	6.875	33.591
9	.1495	3.7973	6.250	30.537
10	.1345	3.4163	5.625	27.483
11	.1196	3.0378	5.000	24.429
12	.1046	2.6568	4.375	21.376
13	.0897	2.2784	3.750	18.322
14	.0747	1.8974	3.125	15.268
15	.0673	1.7094	2.813	13.744
16	.0598	1.5189	2.500	12.215
17	.0538	1.3665	2.250	10.993
18	.0478	1.2141	2.000	9.772
19	.0418	1.0617	1.750	8.550
20	.0359	0.9119	1.500	7.329
21	.0329	0.8357	1.375	6.718
22	.0299	0.7595	1.250	6.107
23	.0269	0.6833	1.125	5.497
24	.0239	0.6071	1.000	4.886
25	.0209	0.5309	0.875	4.275
26	.0179	0.4547	0.750	3.664
27	.0164	0.4166	0.688	3.361

Fractions to Equivalent Decimal Values

FRACTION	DECIMAL
1/64	.016
1/32	.031
3/64	.047
1/16	.063
5/64	.078
3/32	.094
7/64	.109
1/8	.125
9/64	.141
5/32	.156
11/64	.172
3/16	.188
13/64	.203
7/32	.219
15/64	.234
1/4	.250
17/64	.266
9/32	.281
19/64	.297
5/16	.313
21/64	.328
11/32	.344

FRACTION	DECIMAL
23/64	.359
3/8	.375
25/64	.391
13/32	.406
27/64	.422
7/16	.438
29/64	.453
15/32	.469
31/64	.484
1/2	.500
33/64	.516
17/32	.531
35/64	.547
9/16	.563
37/64	.578
19/32	.594
39/64	.609
5/8	.625
41/64	.641
21/32	.656
43/64	.672
11/16	.688

FRACTION	DECIMAL
45/64	.703
23/32	.719
47/64	.734
3/4	.750
49/64	.766
25/32	.781
51/64	.797
13/16	.813
53/64	.828
27/32	.844
55/64	.859
7/8	.875
57/64	.861
29/32	.906
59/64	.922
15/16	.938
61/64	.953
31/32	.969
63/64	.984
1	1.00

Temperature Conversions

°C	°F	°C	°F	°C	°F	°C	°F	°C	°F	°C	°F
-40	-40.0	-2	28.4	36	96.8	74	165.2	160	320	350	662
-39	-38.2	-1	30.2	37	98.6	75	167.0	165	329	355	671
-38	-36.4	0	32.0	38	100.4	76	168.8	170	338	360	680
-37	-34.6	1	33.8	39	102.2	77	170.6	175	347	365	689
-36	-32.8	2	35.6	40	104.0	78	172.4	180	356	370	698
-35	-31.0	3	37.4	41	105.8	79	174.2	185	365	375	707
-34	-29.2	4	39.2	42	107.6	80	176.0	190	374	380	716
-33	-27.4	5	41.0	43	109.4	81	177.8	195	383	385	725
-32	-25.6	6	42.8	44	111.2	82	179.6	200	392	390	734
-31	-23.8	7	44.6	45	113.0	83	181.4	205	401	395	743
-30	-22.0	8	46.4	46	114.8	84	183.2	210	410	400	752
-29	-20.2	9	48.2	47	116.6	85	185.0	215	419	410	770
-28	-18.4	10	50.0	48	118.4	86	186.8	220	428	420	788
-27	-16.6	11	51.8	49	120.2	87	188.6	225	437	430	806
-26	-14.8	12	53.6	50	122.0	88	190.4	230	446	440	824
-25	-13.0	13	55.4	51	123.8	89	192.2	235	455	450	842
-24	-11.2	14	57.2	52	125.6	90	194.0	240	464	460	860
-23	-9.4	15	59.0	53	127.4	91	195.8	245	473	470	878
-22	-7.6	16	60.8	54	129.2	92	197.6	250	482	480	896
-21	-5.8	17	62.6	55	131.0	93	199.4	255	491	490	914
-20	-4.0	18	64.4	56	132.8	94	201.2	260	500	500	932
-19	-2.2	19	66.2	57	134.6	95	203.0	265	509	510	950
-18	-0.4	20	68.0	58	136.4	96	204.8	270	518	520	968
-17	1.4	21	69.8	59	138.2	97	206.6	275	527	530	986
-16	3.2	22	71.6	60	140.0	98	208.4	280	536	540	1004
-15	5.0	23	73.4	61	141.8	99	210.2	285	545	550	1022
-14	6.8	24	75.2	62	143.6	100	212.0	290	554	560	1040
-13	8.6	25	77.0	63	145.4	105	221.0	295	563	570	1058
-12	10.4	26	78.8	64	147.2	110	230.0	300	572	580	1076
-11	12.2	27	80.6	65	149.0	115	239.0	305	581	590	1094
-10	14.4	28	82.4	66	150.8	120	248.0	310	590	600	1112
-9	15.8	29	84.2	67	152.6	125	257.0	315	599	650	1202
-8	17.6	30	86.0	68	154.4	130	266.0	320	608	700	1292
-7	19.4	31	87.8	69	156.2	135	275.0	325	617	750	1382
-6	21.2	32	89.6	70	158.0	140	284.0	330	626	800	1472
-5	23.0	33	91.4	71	159.8	145	293.0	335	635		
-4	24.8	34	93.2	72	161.6	150	302.0	340	644		
-3	26.6	35	95.0	73	163.4	155	311.0	345	653		



Aerovent

A Twin City Fan Company

5959 Trenton Lane · Minneapolis, MN 55442-3237

Phone (763) 551-7500 · Fax (763) 551-7501 · www.aerovent.com



MEMBER



CERTIFIED